



**DEPARTMENT OF  
EDUCATION SERVICES**  
CAYMAN ISLANDS GOVERNMENT

Department of Education Services  
130 Thomas Russell Way,  
P.O. Box 910, Grand Cayman,  
KY1-1103, CAYMAN ISLANDS  
t. (345) 945-1199 f. (345) 945-1457  
[www.education.gov.ky](http://www.education.gov.ky)

September 15, 2015

To: Parents/Guardians and Staff

**Re: AC Problems at Prospect Primary School**

On Wednesday September 9<sup>th</sup> in the afternoon, a leak was detected from an underground pipe to the AC chiller units at Prospect Primary School. Repairs to this leak were slated to be repaired by Thursday morning. Once it became evident that the problem could not be fully corrected in time for start of school Thursday, fans for each room were sourced and put in classrooms and public areas. The timeline on the repair was extended to mid-day Friday once the scope of the issue proved more extensive than previously thought, however, despite a coordinated effort to fix the problem, the repairs were incomplete with the timeline moved to over the weekend.

The AC was up and running at 7a.m. Monday morning, though not at full capacity, however both units failed prior to the start of school. Further work was carried out and by 9a.m. Monday, one of the units was back up and remained operational for the day. Works continued on the system throughout the day and by 10p.m. both units were operational.

We sincerely apologize for any discomfort or inconvenience caused to staff and students during this period.

Yours faithfully,

A handwritten signature in cursive script, appearing to read 'Monteith'.

Lyneth Monteith (Mrs.)  
Actg. Chief Education Officer